



# LINK BOX TECHNICAL DATA SHEET

### Drw. No. 08.08.03 Article No. 010403001/0

	Issued Date: Rev. Date:	10.05.2019	
	Rev. Date:	12.08.202 01	
Гуре	LB.W. E	. 3.1	
- Description	Three Phase Earthing Link Box for		
- Designation		Wall Typ	
- Bonding		Earthin	
- Sheath Voltage Limiter	N/A		
- Phase No.			
Earth			
Drawing Number		08.08.0	
- Article No	010403001/0		
Electrical Characteristics			
- Rated Frequency	50/60	Н	
- SVL Type (*)		N/.	
Protection Class		IP 6	
Naterial			
- Enclosure	Stainless Steel AISI304 (AISI	1316 optiona	
- Body Thickness (**)		2 mr	
- Cover Thickness	3 mm		
- Connection Links	10 µm Tinned Electrolytic Copper		
- Connection Links Dimension	50x10 mm (500 mm2)		
- Gasket	Silicone		
- Cable Glands	4x48 mm		
- Cable Glands Insulation	Silicone gasket & EPR tape		
- Insulation	Epoxy Support Insulato		
- Conductor Fixing	Conductor Flexconn - 400-500 mm		
- Painting Process	Electro Static Polyester Powder Pain		
- Painting Code	Electro Static Polyester Powder Pain RAL 7032		
- Labeling Material	RAL 7032 Stainless Steel		
- Protection Cover	Stainess Ster		
AC Impulse Test			
- Phase-to-Phase	N/A	k	
- Phase-to-Earth	37,5	k	
/oltage Withstand Test			
- AC	20	kV/1 mi	
- DC	25	kV/5 mi	
Short Circuit Test			
- Symmetrical	63	kA/1se	
		· • /- ·	
nternal Power Arcing Test (Symmetrical)	40	kA/0.1 se	

\* In case of mismatch in given values, technical drawing provided along with the Order Confirmation is valid. Ask for conformity if SVL is out of EMELEC's scope.

\*\* Body Thickness might differ related to technical drawing revision. For exact value, refer to technical drawing provided along with the Order Confirmation

#### Bonding Cable

Cross-Section (mm2)     Outer     Inner     min     max (mm)     min
300-500 48 44 20 28 22 40 N/A N/A N/A N/A
60

Schematic Diagram

2 10946 LINK BOX 3 EARTHING BUS BAR CABLE END FIXING DISCONNECT LINK BAR BONDING CABLE

## Enclosure Dimensions (\*)

Width	800 mm	
Length	650 mm	
 Heigth	390 mm	
 Weigth	63 kg	

#### Filling Compund (Optional)

Volume N/A

Scheme and dimensions are not to be mentioned as final drawing. For exact dimensions, refer to technical drawing provided along with the Order Confirmation
Given are approximate values. Actual values might slightly differ.

⊲⊺ ⊚I