



## **LINK BOX TECHNICAL DATA SHEET**

Drw. No. 10.04.08 Article No. 12408001/0

 Issued Date:
 4.08.2021

 Rev. Date:


 Rev.
 00

| Туре                                     | LB. W. E . 4.1   |  |  |
|--|--|--|--|
| - Description                            | Four Phase Earthing Link Box for Single Cable                    |  |  |
| - Designation                            | Wall Type  |  |  |
| - Bonding                                | Earthing   |  |  |
| - Sheath Voltage Limiter                 | N/A  |  |  |
| - Phase No.                              | 4  |  |  |
| Earth                                    | 1  |  |  |
| Drawing Number                           | 10.04.08   |  |  |
| - Article No                             | 12408001/0   |  |  |
| Electrical Characteristics               |  |  |  |
| - Rated Frequency                        | 50/60 Hz   |  |  |
| - SVL Type (*)                           | N/A  |  |  |
| Protection Class                         | IP 68  |  |  |
| Material                                 |  |  |  |
| - Enclosure                              | Stainless Steel AISI304 (AISI316 optional)                       |  |  |
| - Body Thickness (**)                    | 3 mm   |  |  |
| - Cover Thickness                        | 3 mm   |  |  |
| - Connection Links                       | 10 μm Tinned Electrolytic Copper                                 |  |  |
| - Connection Links Dimension             | 40x10 mm (400 mm2)   |  |  |
| - Gasket                                 | Silicone   |  |  |
| - Cable Glands                           | 5x48 mm  |  |  |
| - Cable Glands Insulation                | Silicone gasket & EPR tape & Mastic Tape & Heat Shirinkable Tube |  |  |
| - Insulation                             | Epoxy Support Insulator  |  |  |
| - Conductor Fixing                       | Conductor Flexconn - 95-400 mm2                                  |  |  |
| - Painting Process                       | Electro Static Polyester Powder Paint                            |  |  |
| - Painting Code                          | RAL 7032   |  |  |
| - Labeling Material                      | Stainless Steel  |  |  |
| - Protection Cover                       | PET-G  |  |  |
| AC Impulse Test                          |  |  |  |
| - Phase-to-Phase                         | N/A kV   |  |  |
| - Phase-to-Earth                         | 40 kV  |  |  |
| Voltage Withstand Test                   |  |  |  |
| - AC                                     | 20 kV/1 min  |  |  |
| - DC                                     | 25 kV/5 min  |  |  |
| Short Circuit Test                       |  |  |  |
| - Symmetrical                            | 50 kA/1sec   |  |  |
| Internal Power Arcing Test (Symmetrical) | 40 kA/0.1 sec  |  |  |
| mornari oner Archig rest (cyminetrical)  | 40 KA/U. I Sec   |  |  |

<sup>\*</sup> In case of mismatch in given values, technical drawing provided along with the Order Confirmation is valid. Ask for conformity if SVL is out of EMELEC's scope.


<sup>\*\*</sup> Body Thickness might differ related to technical drawing revision. For exact value, refer to technical drawing provided along with the Order Confirmation

## Bonding Cable



Ø.

## Schematic Diagram



## Enclosure Dimensions (\*)

| Width                      | 780 mm |  |  |
|----------------------------|--------|--|--|
| Length                     | 500 mm |  |  |
| Heigth                     | 250 mm |  |  |
| Weigth                     | 64 kg  |  |  |
| Filling Compund (Optional) |        |  |  |
| Volume                     | N/A    |  |  |

<sup>\*</sup> Scheme and dimensions are not to be mentioned as final drawing. For exact dimensions, refer to technical drawing provided along with the Order Confirmation

<sup>\*\*</sup> Given are approximate values. Actual values might sligthly differ.